



3420 Highway 167 North
PO Box 90866
Lafayette, Louisiana 70509-0866

337/896-5384
Fax: 337/896-2533

www.slemco.com

METERS, INACCESSIBLE

A number of meters have been installed during the elevation of homes and are inaccessible to SLEMCO employees. When this is discovered the owner will be notified by certified mail and given 30 days to have the electrical work performed or service will be disconnected.

At the end of the 30-day period the meter must meet the SLEMCO service entrance requirements or service will be disconnected.

No consumer will be connected with an inaccessible meter.

Overhead and Underground Service Requirements can be found on the SLEMCO website (www.slemco.com) under the heading **SERVICE AND PRODUCTS** and **SERVICE SPECS** tab.

*NOTE: The meter base shall be furnished and installed by customer. Meter base shall be mounted between 5' and 6' (feet) above finished grade. If meter base has been installed at a higher level, a sturdy platform with permanent steps shall be constructed out of treated lumber or some other non-corrosive material in order to achieve required specifications.